

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 115

Dated: 18.03.26

It is certified that an inspection team headed by Pankaj Kumar J.E.

(Name of Officers with designation) from P.H. Section Bikramganj PHED

inspected the D.A.V. PUBLIC SCHOOL ARA ROAD TENDUNI CHOWK, BIKRAMGANJ

(Name & Address of the school) on 18/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. - dated 28/02/2026


of DIVISIONAL LABORATORY (SSM) (PHED Lab) certified that

the D.A.V. PUBLIC SCHOOL BIKRAMGANJ (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 17/03/2027.

Signature with Seal: 

Name

: Sumit Kumar

Designation

: A.E. cum

Name & Address of the Office / Department : P.H. Sub

division

Bikramganj

Rohtas

To

D.A.V. PUBLIC SCHOOL ARA ROAD  
TENDUNI CHOWK, BIKRAMGANJ  
(Name & Address of the Institution)  
ROHTAS, BIHAR, PIN - 802212

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**Office of the Executive Engineer  
Public Health Engineering Department, Sasaram (Rohtas)**

Divisional Laboratory:- Sasaram

(Values In mg /Lit. except pH. Otherwise mentioned)

Zone :- Patna		Division Name: SASARAM										Date:-28/02/2026						
Sl. No.	Block	Panchayat	Village	Location of Source	pH	Turb	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	No3	So4	F	Total Coli.
1	Bikramganj	D.A.V.School Ara Road Tenduni chok Bikaramganj		D.A.V.School Ara Road Tenduni chok Bikaramganj	6.5	<0.5	140	92	60	18	3.65	12	70	0.1	BDL	5	0.102	Negative
<b>Desirable Limit</b>					6.5-8.5	1		500	200	75.0	30.00	250	200	1	45	200	1	
<b>Drinking Water Specification (Second Revision) IS 10500 /2012 Permissible limit in absence of alternate source</b>					NR	5.0 NTU	-	2000	600	200	100	1000	600	NR	NR	400	1.5	

Note:- Sample collected By - D.A.V.School Staff

BDL- Below detection limit

*P. Kumar*  
28/02/2026  
Chemist

P.H.Division.Sasaram

*Alok Kumar*  
28/02/2026  
Executive Engineer  
P.H.Division.Sasaram